Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
PV 50637466 0001

Berichtsnummer *Report No.:*
CN246HM6 001

Genehmigungsinhaber *License Holder:*
Changzhou EGing Photovoltaic
Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town
Jintan City
213213 Jiangsu
P.R. China

Fertigungsstätte *Manufacturing Site:*
Changzhou EGing Photovoltaic
Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town
Jintan City
213213 Jiangsu
P.R. China

Prüfzeichen *Test Mark:*

TÜVRheinland CERTIFIED
IEC 61215
IEC 61730
Regular Production Surveillance
www.tuv.com
ID 1111287601

Geprüft nach *Tested according to:*
IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023
EN IEC 61215-1:2021
EN IEC 61215-1-1:2021
EN IEC 61215-2:2021
EN IEC 61730-1:2018
EN IEC 61730-2:2018

Geräteidentifikation
Product Identification

Produkt: PV Module
Product:

Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: *Type designation(s) are listed on the next page(s)*

Technische Daten: Class II acc. to IEC 61140
Technical Data: For other ratings, refer to the test report.

Gültig bis: 2029-06-30
Date of expiry:

Gültig ab: 2024-07-01
Valid from:

Ausstellungsdatum: 2024-07-01
Date of issue:

Zertifizierungsstelle:
Certification body:

TÜV Rheinland LGA Products GmbH TÜVRheinland Zertifizierungsstelle

Angela Yao

® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
PV 50637466 0001

Berichtsnummer *Report No.:*
CN246HM6 001

Produkt *Product:* PV Module

Modell *Type:*

Bezeichnung *Designation:*

Max. system voltage: up to 1500 VDC (Voc at STC):
With cut of mono c-Si cells:
EG-xxxNT78-HLV (xxx=605-625, in steps of 5, 156 cells)
EG-xxxNT72-HLV (xxx=560-595, in steps of 5, 144 cells)
EG-xxxNT60-HLV (xxx=455-495, in steps of 5, 120 cells)
EG-xxxNT54-HLV (xxx=420-450, in steps of 5, 108 cells)
EG-xxxNT32-HLV (xxx=250-264, in steps of 2, 64 cells)
EG-xxxNT16-HLV (xxx=120-132, in steps of 2, 32 cells)
EG-xxxNT72-HRaV (xxx=580-620, in steps of 5, 144 cells)
EG-xxxNT60-HRaV (xxx=480-510, in steps of 5, 120 cells)
EG-xxxNT54-HRaV (xxx=435-460, in steps of 5, 108 cells)
EG-xxxNT72-HRbV (xxx=575-610, in steps of 5, 144 cells)
EG-xxxNT60-HRbV (xxx=475-510, in steps of 5, 120 cells)
EG-xxxNT54-HRbV (xxx=425-460, in steps of 5, 108 cells)
EG-xxxNT66-HRcV (xxx=585-615, in steps of 5, 132 cells)
EG-xxxM66-HUV (xxx=640-670, in steps of 5, 132 cells)
EG-xxxM60-HUV (xxx=540-620, in steps of 5, 120 cells)
EG-xxxM54-HUV (xxx=490-555, in steps of 5, 108 cells)
EG-xxxM78-HLV (xxx=585-605, in steps of 5, 156 cells)
EG-xxxM72-HLV (xxx=530-560, in steps of 5, 144 cells)
EG-xxxM60-HLV (xxx=440-465, in steps of 5, 120 cells)
EG-xxxM54-HLV (xxx=395-420, in steps of 5, 108 cells)
xxx represents output power in Wp

Remarks:
Fire Rating: Class C (according to UL 790)
Design Load / Safety Factors: 3600 Pa / 1.5 (downward)
1600 Pa / 1.5 (upward)

Conditions:
The product test is voluntarily according to technical regulations.
Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

TÜV Rheinland LGA Products GmbH
TÜVRheinland
Zertifizierungsstelle

® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.